



ALTERATIONS TO SPACE CONDITIONING SYSTEMS (FORMERLY CF-1R-ALT-HVAC)

CF1R-ALT-02-E

(Page 1 of 3)

CERTIFICATE OF COMPLIANCE

Project Name:	Martinez - 3401 Yerington Ct.	Enforcement Agency:	City of Modesto
Dwelling Address:	3401 Yerington Court	Permit Number:	TBD
City and Zip Code	Modesto, 95355	Permit Application Date:	

A. General Information					
CF1R-ALT-02 is applicable to multiple space conditioning systems contained within a single dwelling unit.					
01	Project Name	Martinez - 3401 Yerington Ct.	02	Date Prepared	2023-08-25
03	Project Location	3401 Yerington Court	04	Building Type	Single family
05	CA City	Modesto	06	Dwelling Unit Name	Martinez - 3401 Yerington Ct.
07	Zip Code	95355	08	Dwelling Unit Conditioned Floor Area (ft²)	2737
09	Climate Zone	12	10	Number of Space Conditioning (SC) Systems in this Dwelling Unit:	1

B. Space Conditioning (SC) System Information									
01	02	03	04	05	06	07	08	09	10
SC System ID or Name	SC System Location or Area Served	CFA served by this SC System (ft ²)	Is the SC system a ducted system?	Installing a refrigerant containing component?	Installing new SC system components?	Installing more than 25 feet of ducts?	Installing entirely new duct system?	Installing entirely new SC system?	Alteration Type
System 1	Location 1	2737	Yes	Yes	Yes	No	No	No	Altered space conditioning system

ALTERATIONS TO SPACE CONDITIONING SYSTEMS (FORMERLY CF-1R-ALT-HVAC)

C. Extension of Existing Duct System, Greater Than 25 Feet (Section 150.2(b)1Diib)

This section does not apply to this project.

D. Altered Space Conditioning System (Sections 150.2(b)1E and F)

01	02	03	04	05	06	07	08	09	010	11	12	13	14
System ID/ Name	SC System Description of Area Served	Heating System Type	Altered Heating Component s	Heating Efficiency Type	Heating Minimum Efficiency Value	Cooling System Type	Altered Cooling Component s	Cooling Efficiency Type	Cooling Minimum Efficiency Value SEER/SEER2	Cooling Minimum Efficiency Value EER/EER2/C EER	Required Thermostat Type	New or Replaced Duct Length	New Duct R-Value
System 1	Location 1	Central gas furnace	All new heating components	AFUE	80	Central split AC	All new cooling components	EERSEER	17	11.7	Setback	n/a	n/a

Required Documentation:

CF2R-MCH-01-E - Space Conditioning Systems

- Duct insulation requirement for the new portions of supply-air and return-air ducts or plenums: R6 (CZ 3, 5-7) and R8 (CZ 1, 2, 4, 8-16)
- CF2R and CF3R-MCH-20-H - Duct Leakage Test required when heating or cooling components are installed in ducted systems, or when more than 25 ft of duct length is replaced
- Leakage rate compliance: less than or equal to 10% or less than or equal to 7% leakage to outside, or seal all accessible leaks.
- CF2R and CF3R-MCH-25-H Refrigerant Charge verification required when refrigerant containing components are installed or altered (applicable in CZ 2, 8-15).
- CF2R and CF3R-MCH-23 Airflow Rate greater than or equal to 300 CFM per ton required when MCH-25 is required.

Exceptions:

- Duct systems registered with HERS provider as previously sealed are exempt from MCH-20 Duct Leakage Testing requirements.
- Heating-only systems and Air Handler Furnace changes do not require verification of Air Flow MCH-23, or Refrigerant Charge MCH-25.
- Existing duct systems constructed, insulated or sealed with asbestos are exempt from MCH-20 Duct Leakage Testing requirements.


E. Entirely New or Complete Replacement Duct System, with or without Equipment Changeout (Sections 150.2(b)1Diia and 150.2(b)1E, F)

This section does not apply to this project.

F. Entirely New or Complete Replacement Space Conditioning System (Section 150.2(b)1C)

This section does not apply to this project.

ALTERATIONS TO SPACE CONDITIONING SYSTEMS (FORMERLY CF-1R-ALT-HVAC)

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT		
1. I certify that this Certificate of Compliance documentation is accurate and complete.		
Documentation Author Name: Chris Curtis	Documentation Author Signature: <i>Chris Curtis</i>	
Company: COACHES HVAC EXTRAORDINAIR	Signature Date: 2023-08-25 08:38:02	
Address: 4007 N. Wilson Way	CEA/ HERS Certification Identification (if applicable):	
City/State/Zip: Stockton CA 95205	Phone: 209-230-0651	
RESPONSIBLE PERSON'S DECLARATION STATEMENT		
I certify the following under penalty of perjury, under the laws of the State of California:		
<ol style="list-style-type: none"> 1. The information provided on this Certificate of Compliance is true and correct. 2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer). 3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations. 4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application. 5. I understand that a registered copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections, and I will take the necessary steps to accomplish this requirement. 6. I understand that a registered copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy, and I will take the necessary steps to accomplish these requirements. 		
Responsible Designer Name: Chris Curtis	Responsible Designer Signature: <i>Chris Curtis</i>	
Company : COACHES HVAC EXTRAORDINAIR	Date Signed: 2023-08-25 08:38:02	
Address: 4007 N. Wilson Way	License: 1063779	
City/State/Zip: Stockton CA 95205	Phone: 209-230-0651	Easy to Verify at CalCERTS.com 

Digitally signed by CalCERTS. This digital signature is provided in order to secure the content of this registered document, and in no way implies Registration Provider responsibility for the accuracy of the information.

Registration Number: 223-A020106760A-000-000-0000000-0000

Registration Date/Time: 2023-08-25 08:38:02

HERS Provider: CalCERTS